

Passaic County Department of Health - Incident Report

IR Number	Activity	Program	Incident Date	Incident Time	Date Closed
200542680	REF/DEP	AIR	11/18/2024	12:13 PM	11/18/2024

Investigator: Fen
FileName: Pompton Lakes Borough Municipal Utilities Authority
Incident Address: 326 Pine St.
 Pompton Lakes NJ

Lot	Block	Location	GIS ID
		Multiple locations	

Contact: John Pietrowski **Title:** Superintendent
Phone: (973) 839-3044
Responsible Party: Pompton Lakes MUA
Phone: 9735101341
Address: 2000 Lincoln Ave.
 Pompton Lakes NJ

Report By	Phone	Followups	Next Followup Date	Hours In
Alysha Valencia		0		1.5

DEP Called **DEPCaseNo**
 241118103352

Incident Summary/Notes
 Fen received multiple incidents from DEP for odor complaints alleged to be coming from the MUA's waste water treatment plant located at 2000 Lincoln Ave. Fen went to the one location at 326 Pine St, and did not detect any odors and no one answered the doorbell. Fen proceeded to the MUA and spoke with the Superintendent, John Pietrowski about the numerous odor complaints. Fen did not detect any odors at the facility nor in close proximity. John P. said he had heard of complaints, mainly on Facebook, and while some were nearby, he said others were 2.5 miles from the facility. He stated that nothing has changed at the facility, such as increased flows or upsets. He speculated that some may be coming from the storm sewers or the lake where water levels and rain have contributed to exposure of lake muck that is usually covered as well as sewer gas from the drains. He plans to jet some of the sanitary lines to see if that helps alleviate the problem. Fen did not detect any odors upon leaving the facility and driving through the neighborhood where some of the anonymous complaints stated there were odors. No further action.

Notice of Violation Issued: